

May 2021 Public Utilities Report

1. Parks
 - a. Pier was fixed on 5-6-2021.
 - b. Boat dock will be put in the lake this week.
 - c. Bath house will be opened when chance freezing is not in the forecast.
2. Water
 - a. Wel Inspection Report attachment enclosed.
3. Wastewater
 - a. Discharge is going on schedule.
 - b. Phosphorus discharge level 4.21 mg/l. This is high. Discharge limits should be 1mg/l. We do not have phosphorus limit on discharge yet as we are discharging into the infiltration basins. If we were to discharge in the wetlands this is not acceptable.
4. Recycle center.
 - a. blocks have been placed. We only got 9 of them we will be adding as they are available.
5. Roads
 - a. Roads have been graded, by Driveway Service.