

January 2025 City Council Meeting Report from Utilities Superintendent Mike DuFrane

Water

1. Dakota Fence proposal see attached.
2. Sanitary survey MDH see attached.
3. Total water pumped .664 MG average daily flow .021, highest daily flow .040 in December 2024
4. Total gallons discharge from filter backwash .034 MG in December 2024
5. Chemicals pumped 1.5 gallons of Fluoride, 15.5 gallons of chlorine, 21.0 gallons of polymer, 97 gallons of potassium permanganate in 2024.

Wastewater

1. Influent total gallons .492 MG in December 2024.
2. Quarter results for influent. TSS 174mg/l, CBOD5 251mg/l, Phosphorus 4.95mg/l
3. No discharge for the month of December
4. Pump replacement or repair quote See attached Replacement cost or rebuild bottom of the pump.

Old meters were sold for brass totaling \$872.20 and would like to purchase an air compressor with these funds.