



*Protecting, Maintaining and Improving the Health of All Minnesotans*

July 23, 2025

Vergas City Council  
c/o Julie Lammers, City Clerk  
P.O. Box 32  
Vergas, Minnesota 56587

Dear Council Members:

SUBJECT: Lead/Copper Tap Water Monitoring Report, PWSID 1560029

This letter is to report the results of your recent lead/copper monitoring that is required by the Safe Drinking Water Act. The results revealed the following 90th percentile levels:

90th percentile lead level = 5 µg/l (rounded as 0.005 mg/l).

The action level for lead is 15.0 µg/l.

90th percentile copper level = 1150 µg/l (rounded as 1.150 mg/l).

The action level for copper is 1300 µg/l.

Based on these results, your public water system **has not exceeded** the action level for lead and **has not exceeded** the action level for copper.

By federal rule, 40 CFR 141.85, you are required to provide the lead/copper results to persons served at the sites that were tested. In addition, you must provide them with an explanation of the health effects of lead/copper, list steps consumers can take to reduce exposure to lead/copper in drinking water, and water utility contact information. The notification must also provide the maximum contaminant level goals, the action levels for lead/copper, and the definitions for these two terms.

Notification must be made within 30 days by U.S. Mail, hand/direct delivery, or posting. Please refer to the enclosed Lead/Copper Results Delivery Certification form for delivery method requirements. If the residence is a rental property, both the occupant(s) of the residence and rental property owner must be notified. To assist you in meeting the notification requirements, we have enclosed the results notification letters which must be delivered to the homeowners along with a copy of the fact sheet on lead/copper in drinking water.

The lead/copper sampling site addresses are private data. This information was classified as "nonpublic" by the Minnesota Department of Administration in October 2004, upon the request of Minnesota Department of Health (MDH) and Minnesota community water supply systems. When notifying the persons served at the sites that were tested, provide them with the results for that address only.

Vergas City Council  
Page 2  
July 23, 2025  
PWSID 1560029


Within 10 days after notifying the residents of their results, you must complete the enclosed Lead/Copper Results Delivery Certification form and return it to us. If you chose not to use the results notification letters MDH sent to you and created your own results notification letters, you must submit a copy of one of the letters along with this certification form. The letter you create must contain the same language as the enclosed results notification letters as this is EPA required language. A return envelope is enclosed for your convenience.

Please note that all enclosures are sent to the addressee of this letter. Persons receiving a copy (cc) of the letter do not receive any enclosures. It is the responsibility of the addressee to follow through with the requirements.

A sampling kit will be sent to you prior to your next scheduled sampling date. The enclosed report should be placed in your records and a copy maintained on or near the water supply premises and available for public inspection for not less than ten (10) years.

If you have any questions, please contact me at 651-201-3974 or Jackie Becker at 651-478-0805.

Sincerely,



Stephanie Voeller  
Community Public Water Supply Unit  
Environmental Health Division  
P.O. Box 64975  
St. Paul, Minnesota 55164-0975

PAW  
Enclosures  
cc: Water Superintendent